

Date: 01.12.2020

**CORRIGENDUM - I**

It is notified to all concerned parties that with reference to our Tender No. IITH/CC/SATHYA-P/2020/T010 dated: 06/11/2020 for supply of “Supply of Design, Supply, Installation, Testing, commissioning of basic infrastructure for expansion of IITH data center”., the following changes are being made w.r.t. the Tender: -

Sr. No	Section/Clause	Existing Terms	Amended to
1	5.2. Earnest Money Deposit (EMD)	EMD of Rs. 1,40,000 /-(Rs. One lakh Forty Thousand Only ) in the form of Bank guarantee.	in lieu of Bid Security/EMD, bidders to sign "Bid Security Declaration" accepting that if they withdraw or modify their bids during period of validity etc., they will be suspended for the time specified under the rules. Bids submitted without Bid Security Declaration or relevant Certificates for exemption will stand rejected. <b>The Bidders are required to sign a Bid Securing Declaration as per Annexure.</b>
1	5.2.3.1 Precision Air Conditioners (PAC)	2. blow through direct drive Electronically communicated Motors and Backward curved Plug fans,.	<b>2. blow/draw through</b> direct drive Electronically communicated Motors and Backward curved Plug fans,
2	5.2.3.1 Precision Air Conditioners (PAC)	4.14. Between the fans shall be installed an “S” shape separator design to eliminate turbulence effects of one fan to the others; it shall be also designed to increase efficiency compared to simple plate separator.	<b>4.14. the unit shall be designed to eliminate turbulence effects of one fan to the others;</b> it shall be also designed to increase efficiency compared to simple plate separator.
3	5.2.3.1 Precision Air Conditioners (PAC)	4.15. Filtration shall be provided by deep V form G4 performance dry disposable media to AS1324	<b>Clause Deleted</b>
4	5.2.3.1 Precision Air Conditioners (PAC)	4.26. Microprocessor Control System:- A 32 bit RISC microprocessor shall continuously monitor operation of each Server room air-conditioning unit continuously digitally display room temperature and room relative humidity, alarm on system malfunction and simultaneously display problem.	<b>4.26. Microprocessor Control System:- A microprocessor shall continuously monitor operation of Server room air-conditioning unit continuously digitally display room temperature and room relative humidity, alarm on system malfunction and simultaneously display problem.</b>

5	5.2.3.3 Cold-Aisle Containment	2. Ceiling Panel: Galvanized Steel Framework (600 mm / 800 mm wide) Galvanized Steel is as per "IS 513 Grade D" Toughened Glass or Polycarbonate panel.	2. Ceiling Panel: <b>Aluminium Framework (1.2mm thickness) (600 mm / 800 mm wide) with powder coated black matt finish</b> and Toughened Glass or Polycarbonate panel(4mm thickness).
6	5.2.3.3 Cold-Aisle Containment	3. Doors (Sliding): Galvanized frame (1.2mm thickness) work and toughened glass (4mm thickness) Sliding mechanism or Swivel mechanism with hinges.	3. Doors (Sliding): <b>Aluminium framework (1.2mm thickness) with powder coated black matt finish</b> and toughened glass (4mm thickness) Sliding mechanism or Swivel mechanism with hinges.
7	5.2.3.3 Cold-Aisle Containment	4. Powder Coating: Powder coat is with Nano ceramic pre-treatment process using a zirconium coat. The Powder coating process is ROHS compliant. Powder coating thickness shall be 80 to 100 microns	<b>Clause Deleted</b>
8	5.2.8. Technical Specifications for Raised Flooring System and other Civil Works		<b>5.7 Additional cable tray rack above cabinets and racks shall be installed for laying LAN/Fiber cables between Racks. Bidder shall quote accordingly</b>
9	5.3 List of Approved Makes	1.A. UPS System Schneider / Vertiv / Eaton / Delta  3. Fire Alarm system: Tyco (Simplex), Honeywell (Notifier), Siemens (Fire Finder Series), Schneider	<b>Following makes are included in the list:</b>  <b>1.A. UPS System: Schneider / Vertiv / Eaton / Delta / Numeric (Legrand)</b>  <b>3. Fire Alarm system: Tyco, Honeywell , Siemens, Schneider</b>
10	Chapter-2 5. Performance Bank Guarantee (PBG)	The Successful bidder/Contractor whose tender is accepted, will be required to furnish performance bank guarantee (PBG) of 5% (Five percent) of the tendered amount within the period of 15 days	The Successful bidder/Contractor whose tender is accepted, will be required to furnish performance bank guarantee (PBG) of <b>3% (Three percent)</b> of the tendered amount within the period of 15 days
10	5.2.4. Technical Specifications for Fire Alarm System	Analogue Fire Alarm & Detection System complete with 14 multi-criteria detectors, fault isolator module, monitor & control modules, manual call point & sounders to support integration into the BMS system	<b>Analogue / Conventional Fire Alarm panel System</b>

The pre bid clarifications are uploaded separately.

Other the terms & conditions of the notice published on Institute website

<https://www.iith.ac.in/tenders/> & <https://eprocure.gov.in/epublish/app> and

<https://mhrd.euniwizarde.com> will remain unchanged.

No more correspondence in this regard will be entertained.

## Bid Securing Declaration Form

Date: \_\_\_\_\_

Tender No. \_\_\_\_\_

To (insert complete name and address of the purchaser)

I/We. The undersigned, declare that:

I/We understand that, according to your conditions, bids must be supported by a Bid Securing Declaration.

I/We accept that I/We may be disqualified from bidding for any contract with you for a period of **TWO** years from the date of notification if I am /We are in a breach of any obligation under the bid conditions, because I/We

- a) have withdrawn/modified/amended, impairs or derogates from the tender, my/our Bid during the period of bid validity specified in the form of Bid; or
- b) having been notified of the acceptance of our Bid by the purchaser during the period of bid validity (i) fail or refuse to execute the contract, if required, or (ii) fail or refuse to furnish the Performance Security, in accordance with the Instructions to Bidders.

I/We understand this Bid Securing Declaration shall cease to be valid if I am/we are not the successful Bidder, upon the earlier of (i) the receipt of your notification of the name of the successful Bidder; or (ii) thirty days after the expiration of the validity of my/our Bid.

Signed: \_\_\_\_\_ (insert signature of person whose name and capacity are shown)  
in the capacity of \_\_\_\_\_ (insert legal capacity of person signing the Bid Securing Declaration)

Name: \_\_\_\_\_ (insert complete name of person signing the Bid Securing Declaration)

Duly authorized to sign the bid for an on behalf of (insert complete name of Bidder)

Dated on \_\_\_\_\_ day of \_\_\_\_\_ (insert date of signing)

Corporate Seal (where appropriate)

(Note: In case of a Joint Venture, the Bid Securing Declaration must be in the name of all partners to the Joint Venture that submits the bid)