



ఐఐఐఠి హైదరాబాద్  
आई आई टी हैदराबाद  
IIT Hyderabad

భారతీయ సాంకేతిక విజ్ఞాన సంస్థ హైదరాబాద్  
भारतीय प्रौद्योगिकी संस्थान हैदराबाद  
కంఢీ - 502 284, సాంగారెడ్డి, తెలంగాణ, భారత  
ఫోన్ : (040) 2301 6091; ఫే క్స్ : (040) 2301 6003 / 32  
Indian Institute of Technology Hyderabad  
Kandi - 502 284, Sangareddy, Telangana, INDIA  
Phone: (040) 2301 6091; Fax: (040) 2301 6003 / 32  
Construction and Maintenance Division

F.No: IITH/CMD/F.35/ELE/NIT-05/2022-23/

Date: 19<sup>th</sup> December 2022

**CORRIGENDUM CUM ADDENDUM-1**

**Sub: "5 Years of Operations and Maintenance of 650 KLD Capacity Sewage Treatment Plant -1 (STP-1) at IITH Campus (2<sup>ND</sup> CALL)" –Reg.**

**Ref: Tender No. IITH/CMD/ELE/NIT/2022-23/05 dated: 05.12.2022**

The following terms and conditions has been amended and added as mentioned here under:

Sl. No.	Page No. / Line / Para / Ref no.	"As per Tender"	"Now shall be read as"
1	Page no. 24/Special Conditions of Contract/Point No.31	Contractor shall have to test the effluent/influent at his own cost at the Plant Laboratory on daily basis. The same will be verified by and checked by IITH whenever required.	Contractor shall have to test the effluent/influent at his own cost at the Plant Laboratory on daily basis. The same will be verified by and checked by IITH whenever required. The Effluent Quality Parameters to be tested and maintained: 1) Biological Oxygen Demand 5-day (BOD5) < 5mg/l 2) Total Suspended Solids < 5mg/l 3) Turbidity < 1NTU 4) Hardness of softened water < 50 mg/l 5) Total coliform MPN/100 ml, max < 100 6) Oil and grease - Not detectable 7) Colour and Odour - Clear and Not objectionable 8) Chlorine >1 ppm as total Cl
4		NOT MENTIONED	<b>LIMITATION OF LIABILITY</b> i) Neither Party to this Agreement shall be liable to the other Party for any special, incidental, indirect, punitive or consequential damages, including damages for loss of profits, business, goodwill, revenue or anticipated savings.

			<p>ii) Any other liabilities under the contract not covered above shall be limited to maximum of 100% of the agreed per year contract value (AMC value per year) provided that the foregoing clauses shall not apply to cases of criminal negligence or willful misconduct and to damages awarded in the case of personal injury or death to the extent such damages cannot be disclaimed under the law.</p>
--	--	--	--

*[Handwritten signature]*  
19-12-2022

**Executive Engineer (Electrical)**

---